

~~CONFIDENTIAL~~

ATTN: Executive Officer, OTR
Supply & Services Officer

13 August 1957

Acting Chief, Real Estate and Construction Division, OL

Utilities' Survey - [REDACTED]

25X1A6a

REF: Memo dated 31 July 1957 from Supply and Services Officer, OTR
to Chief, Real Estate and Construction Division, OL
subject "Utilities Survey"

1. In accordance with reference memorandum, a survey of the

25X1A6a

[REDACTED] utilities was made on 7 August 1957.

2. All utility services are satisfactory and are considered
adequate to meet the requirements outlined in reference memorandum.

3. For your information, the following data are given:

- a. Water - 1½ inch supply pipe
- b. Sewerage - 1,200 gallon septic tank
- c. Electricity - single-phase, 120/240 volts,
100 amperes

[REDACTED] 25X1A9a

Distribution:

- Orig. & 1 - Addressee 25X1A6a
- 1 - Station Engineer, [REDACTED]
- 1 - RECD Project
- 1 - RECD Chrono
- 1 - URB/RECD/OL

25X1A9a

OL/RECD: [REDACTED] ;gs/4543 (13 August 1957)

Document No. 10

No Change In Class. ☐

☐ Declassified

Class. Changed To: ☐ 8

Auth.: HR 70-2

By: 825